

FULL FINAL LABORATORY REPORT

LAB NUMBER: UD 00337446

SUBMITTED BY: JH ESTERHUIZEN EH Makana Municipality Medical Officer Po Box 176 Grahamstown Eastern Cape 6140	SAMPLE: ALICEDALE SOURCE: DRINKING WATER Sample Ref: 2 Client Ref No: FINAL RESIVIOR Outbreak Case No: Collected: 09/09/2019 ? Received: 09/09/2019 12:32 Printed: 17/09/2019 08:00	REPORT TO: JH ESTERHUIZEN EH Makana Municipality Medical Officer Po Box 176 Grahamstown Eastern Cape 6140
--	--	---

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water @
@ Test referred to another NHLS laboratory

Potable Water:
Condition on arrival On ice
Coliform count (Colilert) 0 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received

REFERENCE METHOD(S):
Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

@ Potable water referred to Port Elizabeth Laboratory (Tel 041 395 6111)

Authorised by: VC Pearce (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UD 00337444

SUBMITTED BY: JH ESTERHUIZEN EH Makana Municipality Medical Officer Po Box 176 Grahamstown Eastern Cape 6140	SAMPLE: RIEBEECK EAST SOURCE: DRINKING WATER Sample Ref: 1 Client Ref No: FINAL RESIVIOR Outbreak Case No: Collected: 09/09/2019 ? Received: 09/09/2019 12:32 Printed: 17/09/2019 08:00	REPORT TO: JH ESTERHUIZEN EH Makana Municipality Medical Officer Po Box 176 Grahamstown Eastern Cape 6140
--	--	---

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water @
@ Test referred to another NHLS laboratory

Potable Water:
Condition on arrival On ice
Coliform count (Colilert) 0 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received

REFERENCE METHOD(S):
Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

@ Potable water referred to Port Elizabeth Laboratory (Tel 041 395 6111)

Authorised by: VC Pearce (Medical Technologist) Potable water

-- End of Laboratory Report --