

FULL FINAL LABORATORY REPORT

LAB NUMBER: UD 00336659

SAMPLE: ENVIRONMENTAL
SOURCE:

SUBMITTED BY:
EH Makana Municipality
Medical Officer
Po Box 176
Grahamstown
Eastern Cape
6140
T: 0786258873

Sample Ref: 2
Client Ref No: HEALTH OFFICE
Outbreak Case No:
Collected: 03/09/2019
Received: 03/09/2019 09:45
Printed: 06/09/2019 15:51

REPORT TO:
EH Makana Municipality
Medical Officer
Po Box 176
Grahamstown
Eastern Cape
6140

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water @
@ Test referred to another NHLS laboratory

Potable Water:

Condition on arrival On ice
Coliform count (Colilert) 0 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

@ Potable water referred to Port Elizabeth Laboratory (Tel 041 395 6111)

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --