

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 01354886

SAMPLE: K STREET COMMUNAL TAP
SOURCE:

SUBMITTED BY:
MJ GRANT
EH Makana Municipality
Medical Officer
Po Box 176
Grahamstown
Eastern Cape
6140

Sample Ref: PH19/1318
Client Ref No: 5
Outbreak Case No:
Collected: 09/07/2019 10:00
Received: 10/07/2019 15:15
Printed: 12/07/2019 12:21

REPORT TO:
MJ GRANT
EH Makana Municipality
Medical Officer
Po Box 176
Grahamstown
Eastern Cape
6140

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water

Potable Water:

Condition on arrival On ice
Coliform count (Colilert) 0 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --