

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 01431066

**SAMPLE: RIEBEECK EAST**  
**SOURCE:**

**SUBMITTED BY:**  
JH. ESTERHUIZEN  
EH Makana Municipality  
Medical Officer  
Po Box 176  
Grahamstown  
Eastern Cape  
6140

Sample Ref: PH19/2297  
Client Ref No: FINAL RESERVOIR  
Outbreak Case No:  
Collected: 05/11/2019 10:30  
Received: 05/11/2019 13:18  
Printed: 08/11/2019 16:39

**REPORT TO:**  
JH. ESTERHUIZEN  
EH Makana Municipality  
Medical Officer  
Po Box 176  
Grahamstown  
Eastern Cape  
6140

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**

Condition on arrival On ice  
Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

**REFERENCE METHOD(S):**

Coliform Count - Colilert Method.....Colilert SANS 5521  
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Ndalamo (Medical Technologist) Potable water

-- End of Laboratory Report --