

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 01436676

SAMPLE: DRINKING WATER
SOURCE:

SUBMITTED BY:
J. ESTERHUIZEN
EH Makana Municipality
Medical Officer
Po Box 176
Grahamstown
Eastern Cape
6140

Sample Ref: PH19/2398
Client Ref No: RAGLAN RD CLINIC
Outbreak Case No:
Collected: 12/11/2019 09:50
Received: 13/11/2019 09:12
Printed: 15/11/2019 14:15

REPORT TO:
J. ESTERHUIZEN
EH Makana Municipality
Medical Officer
Po Box 176
Grahamstown
Eastern Cape
6140

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water

Potable Water:

Condition on arrival On ice
Coliform count (Colilert) 0 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the
laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Ndalamo (Medical Technologist) Potable water

-- End of Laboratory Report --