

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 01345635

<b>SUBMITTED BY:</b> P.SIDEBA EH Makana Municipality Medical Officer Po Box 176 Grahamstown Eastern Cape 6140	<b>SAMPLE:</b> INDOOR SPORT CENTRE <b>SOURCE:</b> TAP WATER  Sample Ref: PH19/1193 Client Ref No: 08:05 Outbreak Case No:  Collected: 19/06/2019 10:10 Received: 20/06/2019 10:10 Printed: 27/06/2019 16:00	<b>REPORT TO:</b> P.SIDEBA EH Makana Municipality Medical Officer Po Box 176 Grahamstown Eastern Cape 6140
------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**  
Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received

REFERENCE METHOD(S):  
Coliform Count - Colilert Method.....Colilert SANS 5521  
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: D Bezuidenhout (Medical Technologist) Potable water

-- End of Laboratory Report --

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 01345639

**SUBMITTED BY:**

P.SIDEBA  
EH Makana Municipality  
Medical Officer  
Po Box 176  
Grahamstown  
Eastern Cape  
6140

**SAMPLE:** EXT 7 CLINIC  
**SOURCE:** TAP WATER

Sample Ref: PH19/1194  
Client Ref No: 08:25  
Outbreak Case No:  
Collected: 19/06/2019 10:10  
Received: 20/06/2019 10:10  
Printed: 27/06/2019 16:00

**REPORT TO:**

P.SIDEBA  
EH Makana Municipality  
Medical Officer  
Po Box 176  
Grahamstown  
Eastern Cape  
6140

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**

Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

**WATER DOMESTIC**

ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241

Total bacterial count.....<=1000 per mL

Total coliforms.....<=10 per 100mL

Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received

**REFERENCE METHOD(S):**

Coliform Count - Colilert Method.....Colilert SANS 5521  
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: D Bezuidenhout (Medical Technologist) Potable water

-- End of Laboratory Report --

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 01345644

**SUBMITTED BY:**  
P.SIDEBA  
EH Makana Municipality  
Medical Officer  
Po Box 176  
Grahamstown  
Eastern Cape  
6140

**SAMPLE:** J'STREET COMMUNAL  
**SOURCE:** TAP WATER

Sample Ref: PH11/1195  
Client Ref No: 08:40  
Outbreak Case No:  
Collected: 19/06/2019 10:10  
Received: 20/06/2019 10:10  
Printed: 27/06/2019 16:00

**REPORT TO:**  
P.SIDEBA  
EH Makana Municipality  
Medical Officer  
Po Box 176  
Grahamstown  
Eastern Cape  
6140

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**

Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received

**REFERENCE METHOD(S):**

Coliform Count - Colilert Method.....Colilert SANS 5521  
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: D Bezuidenhout (Medical Technologist) Potable water

-- End of Laboratory Report --

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 01345647

<b>SUBMITTED BY:</b> P.SIDEBA EH Makana Municipality Medical Officer Po Box 176 Grahamstown Eastern Cape 6140	<b>SAMPLE:</b> ENVIROMENTAL HEALTH OFFICE <b>SOURCE:</b> TAP WATER  Sample Ref: PH19/1196 Client Ref No: 09:20 Outbreak Case No:  Collected: 19/06/2019 10:10 Received: 20/06/2019 10:10 Printed: 27/06/2019 16:00	<b>REPORT TO:</b> P.SIDEBA EH Makana Municipality Medical Officer Po Box 176 Grahamstown Eastern Cape 6140
------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**  
Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received

REFERENCE METHOD(S):  
Coliform Count - Colilert Method.....Colilert SANS 5521  
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: D Bezuidenhout (Medical Technologist) Potable water

-- End of Laboratory Report --

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 01345649

<b>SUBMITTED BY:</b>	<b>SAMPLE:</b>	<b>PURIFICATION WORKS</b>	<b>REPORT TO:</b>
P.SIDEBA	<b>SOURCE:</b>	<b>FINAL FLOW</b>	P.SIDEBA
EH Makana Municipality	Sample Ref:	PH19/1197	EH Makana Municipality
Medical Officer	Client Ref No:	09:55	Medical Officer
Po Box 176	Outbreak Case No:		Po Box 176
Grahamstown	Collected:	19/06/2019 10:10	Grahamstown
Eastern Cape	Received:	20/06/2019 10:10	Eastern Cape
6140	Printed:	27/06/2019 16:00	6140

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**

Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

**WATER DOMESTIC**

ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241

Total bacterial count.....<=1000 per mL

Total coliforms.....<=10 per 100mL

Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received

**REFERENCE METHOD(S):**

Coliform Count - Colilert Method.....Colilert SANS 5521

E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: D Bezuidenhout (Medical Technologist) Potable water

-- End of Laboratory Report --