

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 02965369

**SAMPLE: INDOOR SPORT CENTRE**  
**SOURCE: TAP WATER**

**SUBMITTED BY:**  
J ESTERHUIZEN  
EH Sarah Baartman District Municipality  
PO Box 318  
Port Elizabeth  
Eastern Cape  
6000

Sample Ref: 1  
Client Ref No: 1  
Outbreak Case No:  
Collected: 17/02/2026 08:10  
Received: 18/02/2026 11:20  
1st Print: 19/02/2026 14:27  
Reprint: 19/02/2026 14:27

**REPORT TO:**  
J ESTERHUIZEN  
EH Sarah Baartman District Municipality  
PO Box 318  
Port Elizabeth  
Eastern Cape  
6000

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**  
Condition on arrival On ice  
Date of testing 18/02/2026  
Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

REFERENCE METHOD(S):  
Coliform Count - Colilert Method.....Colilert SANS 5521  
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 02965371

**SAMPLE: EXT 7 CLINIC**  
**SOURCE: TAP WATER**

**SUBMITTED BY:**  
J ESTERHUIZEN  
EH Sarah Baartman District Municipality  
PO Box 318  
Port Elizabeth  
Eastern Cape  
6000

Sample Ref: 2  
Client Ref No: 2  
Outbreak Case No:  
Collected: 17/02/2026 08:20  
Received: 18/02/2026 11:20  
1st Print: 19/02/2026 14:28  
Reprint: 19/02/2026 14:28

**REPORT TO:**  
J ESTERHUIZEN  
EH Sarah Baartman District Municipality  
PO Box 318  
Port Elizabeth  
Eastern Cape  
6000

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**

Condition on arrival On ice  
Date of testing 18/02/2026  
Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

**REFERENCE METHOD(S):**

Coliform Count - Colilert Method.....Colilert SANS 5521  
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 02965373

<b>SUBMITTED BY:</b> J ESTERHUIZEN EH Sarah Baartman District Municipality PO Box 318 Port Elizabeth Eastern Cape 6000	<b>SAMPLE:</b> J STR TAP <b>SOURCE:</b> TAP WATER  Sample Ref: 3 Client Ref No: 3 Outbreak Case No:  Collected: 17/02/2026 08:40 Received: 18/02/2026 11:20 1st Print: 19/02/2026 14:29 Reprint: 19/02/2026 14:30	<b>REPORT TO:</b> J ESTERHUIZEN EH Sarah Baartman District Municipality PO Box 318 Port Elizabeth Eastern Cape 6000
--	---	---

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**  
Condition on arrival On ice  
Date of testing 18/02/2026  
Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

REFERENCE METHOD(S):  
Coliform Count - Colilert Method.....Colilert SANS 5521  
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 02965376

**SAMPLE: PURIFICAITON WORKS**  
**SOURCE: FINAL FLOW**

**SUBMITTED BY:**  
J ESTERHUIZEN  
EH Sarah Baartman District Municipality  
PO Box 318  
Port Elizabeth  
Eastern Cape  
6000

Sample Ref: 4  
Client Ref No: 4  
Outbreak Case No:  
Collected: 17/02/2026 09:05  
Received: 18/02/2026 11:20  
1st Print: 19/02/2026 14:57  
Reprint: 19/02/2026 14:57

**REPORT TO:**  
J ESTERHUIZEN  
EH Sarah Baartman District Municipality  
PO Box 318  
Port Elizabeth  
Eastern Cape  
6000

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**

Condition on arrival On ice  
Date of testing 18/02/2026  
Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

**REFERENCE METHOD(S):**

Coliform Count - Colilert Method.....Colilert SANS 5521  
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 02965378

**SAMPLE: FINAL RESIVIOR, RIEBEECK EAST**  
**SOURCE: DRINKING WATER**

**SUBMITTED BY:**  
J ESTERHUIZEN  
EH Sarah Baartman District Municipality  
PO Box 318  
Port Elizabeth  
Eastern Cape  
6000

Sample Ref: 1  
Client Ref No: 1  
Outbreak Case No:  
Collected: 18/02/2026 11:16  
Received: 18/02/2026 11:20  
1st Print: 19/02/2026 14:30  
Reprint: 19/02/2026 14:31

**REPORT TO:**  
J ESTERHUIZEN  
EH Sarah Baartman District Municipality  
PO Box 318  
Port Elizabeth  
Eastern Cape  
6000

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**

Condition on arrival On ice  
Date of testing 18/02/2026  
Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

**REFERENCE METHOD(S):**

Coliform Count - Colilert Method.....Colilert SANS 5521  
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

**FULL FINAL LABORATORY REPORT**

LAB NUMBER: UH 02965380

**SAMPLE: FINAL RESIVIOR, ALICEDALE**  
**SOURCE: DRINKING WATER**

<b>SUBMITTED BY:</b> J ESTERHUIZEN EH Sarah Baartman District Municipality PO Box 318 Port Elizabeth Eastern Cape 6000	Sample Ref: 2 Client Ref No: 2 Outbreak Case No: Collected: 18/02/2026 11:16 Received: 18/02/2026 11:20 1st Print: 19/02/2026 14:31 Reprint: 19/02/2026 14:31	<b>REPORT TO:</b> J ESTERHUIZEN EH Sarah Baartman District Municipality PO Box 318 Port Elizabeth Eastern Cape 6000
--	---	---

**PUBLIC HEALTH**

Specimen received: Water  
Tests requested: Potable water

**Potable Water:**  
Condition on arrival On ice  
Date of testing 18/02/2026  
Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

REFERENCE METHOD(S):  
Coliform Count - Colilert Method.....Colilert SANS 5521  
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --