

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 02974601

SAMPLE: INDOOR SPORT CENTRE
SOURCE: TAP WATER

SUBMITTED BY:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

Sample Ref: 1
Client Ref No: 1
Outbreak Case No:
Collected: 03/03/2026 08:15
Received: 03/03/2026 12:53
1st Print: 05/03/2026 12:21
Reprint: 05/03/2026 12:23

REPORT TO:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water

Potable Water:

Condition on arrival On ice
Date of testing 03/03/2026
Coliform count (Colilert) 0 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the
laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 02974602

SAMPLE: EXT 7 CLINIC
SOURCE: TAP WATER

SUBMITTED BY:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

Sample Ref: 2
Client Ref No: 2
Outbreak Case No:
Collected: 03/03/2026 08:25
Received: 03/03/2026 12:53
1st Print: 05/03/2026 12:22
Reprint: 05/03/2026 12:22

REPORT TO:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water

Potable Water:

Condition on arrival On ice
Date of testing 03/03/2026
Coliform count (Colilert) 0 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the
laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 02974605

SAMPLE: TANTYI CLINIC
SOURCE: TAP WATER

SUBMITTED BY:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

Sample Ref: 3
Client Ref No: 3
Outbreak Case No:
Collected: 03/03/2026 08:40
Received: 03/03/2026 12:53
Printed: 05/03/2026 12:22

REPORT TO:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water

Potable Water:

Condition on arrival On ice
Date of testing 03/03/2026
Coliform count (Colilert) 34 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the
laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 02974606

SAMPLE: PURIFICATION WORKS
SOURCE: FINAL FLOW

SUBMITTED BY:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

Sample Ref: 4
Client Ref No: 4
Outbreak Case No:
Collected: 03/03/2026 09:15
Received: 03/03/2026 12:53
1st Print: 05/03/2026 12:22
Reprint: 05/03/2026 12:22

REPORT TO:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water

Potable Water:

Condition on arrival On ice
Date of testing 03/03/2026
Coliform count (Colilert) 0 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the
laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 02974608

SAMPLE: ENVIRO HEALTH OFFICE
SOURCE: TAP WATER

SUBMITTED BY:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

Sample Ref: 5
Client Ref No: 5
Outbreak Case No:
Collected: 03/03/2026 09:30
Received: 03/03/2026 12:53
1st Print: 05/03/2026 12:22
Reprint: 05/03/2026 12:22

REPORT TO:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water

Potable Water:

Condition on arrival On ice
Date of testing 03/03/2026
Coliform count (Colilert) 0 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the
laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 02974609

SAMPLE: RIEBEECK EAST FINAL RESIVIOR
SOURCE: DRINKING WATER

SUBMITTED BY: JOHANNE ESTERHUIZEN EH Sarah Baartman District Municipality PO Box 318 Port Elizabeth Eastern Cape 6000	Sample Ref: 1 Client Ref No: 1 Outbreak Case No: Collected: 03/03/2026 12:46 Received: 03/03/2026 12:53 1st Print: 05/03/2026 12:24 Reprint: 05/03/2026 12:27	REPORT TO: JOHANNE ESTERHUIZEN EH Sarah Baartman District Municipality PO Box 318 Port Elizabeth Eastern Cape 6000
--	---	---

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water

Potable Water:
Condition on arrival On ice
Date of testing 03/03/2026
Coliform count (Colilert) 18 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the
laboratory.

REFERENCE METHOD(S):
Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 02974612

SAMPLE: ALICEDALE FINAL RESIVIOR
SOURCE: DRINKING WATER

SUBMITTED BY:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

Sample Ref: 2
Client Ref No: 2
Outbreak Case No:
Collected: 03/03/2026 12:46
Received: 03/03/2026 12:53
1st Print: 05/03/2026 12:24
Reprint: 05/03/2026 12:24

REPORT TO:
JOHANNE ESTERHUIZEN
EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

PUBLIC HEALTH

Specimen received: Water
Tests requested: Potable water

Potable Water:

Condition on arrival On ice
Date of testing 03/03/2026
Coliform count (Colilert) 0 per 100ml
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the
laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --