

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03008878

SAMPLE:	TAP WATER 07:35	REPORT TO:
SOURCE:	PH26/00065	
SUBMITTED BY:	Sample Ref: PH26/00065	
	Client Ref No: 1 ENVIRO OFFICE	
	Outbreak Case No:	
EH Sarah Baartman District Municipality	Collected: 21/04/2026 13:20	EH Sarah Baartman District
PO Box 318	Received: 21/04/2026 14:52	PO Box 318
Port Elizabeth	Printed: 28/04/2026 11:00	Port Elizabeth
Eastern Cape		Eastern Cape
6000		6000

PUBLIC HEALTH

Specimen received: Filtered water  
Tests requested: Potable water @  
@ Test referred to another NHLS laboratory

Potable Water:

Condition on arrival	Acceptable
Date of testing	24/04/2026
Total bacterial count	<1 cfu/ml
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC

ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

@ Potable water referred to Green Point Laboratory (Tel 021 417 9354/5)

Authorised by: T Shagane (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03008882

SUBMITTED BY:	SAMPLE: FINAL FLOW 07:50	REPORT TO:
	SOURCE: PH26/00066	
EH Sarah Baartman District Municipality	Sample Ref: PH26/00066	EH Sarah Baartman District Municipality
PO Box 318	Client Ref No: 2 PURIFICATION WORKS	PO Box 318
Port Elizabeth	Outbreak Case No:	Port Elizabeth
Eastern Cape	Collected: 21/04/2026 13:20	Eastern Cape
6000	Received: 21/04/2026 14:52	6000
	Printed: 28/04/2026 11:00	

PUBLIC HEALTH

Specimen received: Filtered water  
Tests requested: Potable water @  
@ Test referred to another NHLS laboratory

Potable Water:

Condition on arrival	Acceptable
Date of testing	24/04/2026
Total bacterial count	<1 cfu/ml
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC

ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241

Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the laboratory.

@ Potable water referred to Green Point Laboratory (Tel 021 417 9354/5)

Authorised by: T Shagane (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03008883

<b>SUBMITTED BY:</b>	<b>SAMPLE:</b> WATER 08:10 3	<b>REPORT TO:</b>
	<b>SOURCE:</b> PH26/00068	
EH Sarah Baartman District Municipality	Sample Ref: PH26/00067	EH Sarah Baartman District
PO Box 318	Client Ref No: TANTYI CLINIC	PO Box 318
Port Elizabeth	Outbreak Case No:	Port Elizabeth
Eastern Cape	Collected: 21/04/2026 12:30	Eastern Cape
6000	Received: 21/04/2026 14:52	6000
	Printed: 28/04/2026 11:00	

PUBLIC HEALTH

Specimen received: Filtered water  
Tests requested: Potable water @  
@ Test referred to another NHLS laboratory

**Potable Water:**  
Condition on arrival Acceptable  
Date of testing 23/04/2026  
Total bacterial count 83 cfu/ml  
Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

@ Potable water referred to Green Point Laboratory (Tel 021 417 9354/5)

Authorised by: T Shagane (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03008886

<b>SUBMITTED BY:</b>	<b>SAMPLE:</b> WATER 08:10	<b>REPORT TO:</b>
	<b>SOURCE:</b> PH26/00068	
EH Sarah Baartman District Municipality PO Box 318 Port Elizabeth Eastern Cape 6000	Sample Ref: PH26/00068 Client Ref No: INDOOR SPORT Outbreak Case No: Collected: 21/04/2026 13:20 Received: 21/04/2026 14:52 Printed: 28/04/2026 11:00	EH Sarah Baartman District CENTRE PO Box 318 Port Elizabeth Eastern Cape 6000

PUBLIC HEALTH

Specimen received: Filtered water  
Tests requested: Potable water @  
@ Test referred to another NHLS laboratory

Potable Water:

Condition on arrival	Acceptable
Date of testing	24/04/2026
Total bacterial count	<1 cfu/ml
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC

ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

@ Potable water referred to Green Point Laboratory (Tel 021 417 9354/5)

Authorised by: T Shagane (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03008888

<b>SUBMITTED BY:</b>	<b>SAMPLE:</b> WATER 08:45	<b>REPORT TO:</b>
	<b>SOURCE:</b> PH26/00069	
EH Sarah Baartman District Municipality PO Box 318 Port Elizabeth Eastern Cape 6000	Sample Ref: PH26/00069 Client Ref No: EXT 7 CLINIC Outbreak Case No: Collected: 21/04/2026 13:20 Received: 21/04/2026 14:52 Printed: 28/04/2026 11:00	EH Sarah Baartman District Municipality PO Box 318 Port Elizabeth Eastern Cape 6000

PUBLIC HEALTH

Specimen received: Filtered water  
Tests requested: Potable water @  
@ Test referred to another NHLS laboratory

**Potable Water:**

Condition on arrival	Acceptable
Date of testing	23/04/2026
Total bacterial count	<1 cfu/ml
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the laboratory.

@ Potable water referred to Green Point Laboratory (Tel 021 417 9354/5)

Authorised by: T Shagane (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03008890

<b>SUBMITTED BY:</b>	<b>SAMPLE:</b> DRINKING WATER	<b>REPORT TO:</b>
	<b>SOURCE:</b> FINAL RESIVIOR 10H01	
EH Sarah Baartman District Municipality PO Box 318 Port Elizabeth Eastern Cape 6000	Sample Ref: PH26/00070 Client Ref No: RIEBERECK EAST Outbreak Case No: Collected: 21/04/2026 13:20 Received: 21/04/2026 14:52 Printed: 28/04/2026 11:00	EH Sarah Baartman District PO Box 318 Port Elizabeth Eastern Cape 6000

PUBLIC HEALTH

Specimen received: Filtered water  
Tests requested: Potable water @  
@ Test referred to another NHLS laboratory

Potable Water:

Condition on arrival	Acceptable
Date of testing	23/04/2026
Total bacterial count	<1 cfu/ml
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

@ Potable water referred to Green Point Laboratory (Tel 021 417 9354/5)

Authorised by: T Shagane (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03008893

<b>SUBMITTED BY:</b>	<b>SAMPLE:</b> DRINKING WATER	
	<b>SOURCE:</b> FINAL RESIVOIR 10H59	
EH Sarah Baartman District Municipality PO Box 318 Port Elizabeth Eastern Cape 6000	Sample Ref: PH26/00071 Client Ref No: ALICEDALE Outbreak Case No: Collected: 21/04/2026 13:20 Received: 21/04/2026 14:52 Printed: 28/04/2026 11:00	<b>REPORT TO:</b> EH Sarah Baartman District PO Box 318 Port Elizabeth Eastern Cape 6000

PUBLIC HEALTH

Specimen received: Filtered water  
Tests requested: Potable water @  
@ Test referred to another NHLS laboratory

**Potable Water:**  
Condition on arrival Acceptable  
Date of testing 23/04/2026  
Total bacterial count <1 cfu/ml  
Coliform count (Colilert) 0 per 100ml  
E coli count (Colilert) 0 per 100ml

WATER DOMESTIC  
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241  
Total bacterial count.....<=1000 per mL  
Total coliforms.....<=10 per 100mL  
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received  
This report shall not be reproduced except in full, without the approval of the  
laboratory.

@ Potable water referred to Green Point Laboratory (Tel 021 417 9354/5)

Authorised by: T Shagane (Medical Technologist) Potable water

-- End of Laboratory Report --