

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03057449

SUBMITTED BY:	SAMPLE: FINAL RESIVOR	REPORT TO:
	SOURCE: DRINKING WATER	
EH Sarah Baartman District Municipality	Sample Ref: RIEBECK EAST	EH Sarah Baartman District Municipality
PO Box 318	Client Ref No: RIEBECK EAST	PO Box 318
Port Elizabeth	Outbreak Case No:	Port Elizabeth
Eastern Cape	Collected: 14/07/2026 12:08	Eastern Cape
6000	Received: 14/07/2026 12:10	6000
	Printed: 15/07/2026 12:12	

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	On ice
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC

ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241

Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Ndalamo (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03057436

SUBMITTED BY:	SAMPLE: DRINKING WATER	REPORT TO:
	SOURCE: MAKANA ENVIRO OFFICE	
EH Sarah Baartman District Municipality	Sample Ref: 1	EH Sarah Baartman District Municipality
PO Box 318	Client Ref No: 1	PO Box 318
Port Elizabeth	Outbreak Case No:	Port Elizabeth
Eastern Cape	Collected: 14/07/2026 07:30	Eastern Cape
6000	Received: 14/07/2026 12:10	6000
	Printed: 15/07/2026 12:14	

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	On ice
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC

ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241

Total bacterial count..... ≤ 1000 per mL
Total coliforms..... ≤ 10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Ndalamo (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03057438

SUBMITTED BY:	SAMPLE: WAAINEK PURIFICATION	REPORT TO:
	SOURCE: DRINKING WATER	
EH Sarah Baartman District Municipality	Sample Ref: 2	EH Sarah Baartman District Muni
PO Box 318	Client Ref No: 2	PO Box 318
Port Elizabeth	Outbreak Case No:	Port Elizabeth
Eastern Cape	Collected: 14/07/2026 07:30	Eastern Cape
6000	Received: 14/07/2026 12:10	6000
	Printed: 15/07/2026 12:15	

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	On ice
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC

ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241

Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the
laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Ndalamo (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03057440

SUBMITTED BY:	SAMPLE: INDOA SPORTS CENTRE	REPORT TO:
	SOURCE: DRINKING WATER	
EH Sarah Baartman District Municipality	Sample Ref: 3	EH Sarah Baartman District Municipality
PO Box 318	Client Ref No: 3	PO Box 318
Port Elizabeth	Outbreak Case No:	Port Elizabeth
Eastern Cape	Collected: 14/07/2026 07:30	Eastern Cape
6000	Received: 14/07/2026 12:10	6000
	Printed: 15/07/2026 12:15	

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	On ice
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC

ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241

Total bacterial count..... ≤ 1000 per mL
Total coliforms..... ≤ 10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Ndalamo (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03057444

SUBMITTED BY:	SAMPLE: J STREET TAP	REPORT TO:
	SOURCE: DRINKING WATER	
EH Sarah Baartman District Municipality	Sample Ref: 4	EH Sarah Baartman District Municipality
PO Box 318	Client Ref No: 4	PO Box 318
Port Elizabeth	Outbreak Case No:	Port Elizabeth
Eastern Cape	Collected: 14/07/2026 07:30	Eastern Cape
6000	Received: 14/07/2026 12:10	6000
	Printed: 15/07/2026 12:16	

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	On ice
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC

ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241

Total bacterial count..... ≤ 1000 per mL
Total coliforms..... ≤ 10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Ndalamo (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03057446

SUBMITTED BY:	SAMPLE: EXT 7 CLINIC	REPORT TO:
	SOURCE: DRINKING WATER	
EH Sarah Baartman District Municipality	Sample Ref: 5	EH Sarah Baartman District Municipality
PO Box 318	Client Ref No: 5	PO Box 318
Port Elizabeth	Outbreak Case No:	Port Elizabeth
Eastern Cape	Collected: 14/07/2026 07:30	Eastern Cape
6000	Received: 14/07/2026 12:10	6000
	Printed: 15/07/2026 12:16	

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	On ice
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC

ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241

Total bacterial count..... ≤ 1000 per mL
Total coliforms..... ≤ 10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Ndalamo (Medical Technologist) Potable water

-- End of Laboratory Report --