

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03080532

SAMPLE:	TANTYI CLINIC	
SOURCE:	TAP WATER 08:05	
SUBMITTED BY:	Sample Ref: 2	REPORT TO:
EH Sarah Baartman District Municipality	Client Ref No: 2	EH Sarah Baartman District Municipality
PO Box 318	Outbreak Case No:	PO Box 318
Port Elizabeth	Collected: 17/08/2026 08:05	Port Elizabeth
Eastern Cape	Received: 17/08/2026 12:25	Eastern Cape
6000	Printed: 21/08/2026 15:07	6000

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	On ice
Date of testing	17/08/2026
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03080533

SAMPLE:	INDOOR SPORT CENTRE	REPORT TO:
SOURCE:	TAP WATER 08:19	
SUBMITTED BY:	Sample Ref: 3	
	Client Ref No: 3	
EH Sarah Baartman District Municipality	Outbreak Case No:	EH Sarah Baartman District Municipality
PO Box 318		PO Box 318
Port Elizabeth	Collected: 17/08/2026 08:19	Port Elizabeth
Eastern Cape	Received: 17/08/2026 12:25	Eastern Cape
6000	1st Print: 21/08/2026 15:14	6000
	Reprint: 21/08/2026 15:14	

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	On ice
Date of testing	17/08/2026
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03080541

SAMPLE: FINAL RESIVIOR
SOURCE:

SUBMITTED BY:

EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

Sample Ref: ALICEDALE
Client Ref No: ALICEDALE
Outbreak Case No:
Collected: 17/08/2026 12:19
Received: 17/08/2026 12:25
1st Print: 21/08/2026 15:23
Reprint: 21/08/2026 15:23

REPORT TO:

EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	On ice
Date of testing	17/08/2026
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03080537

SUBMITTED BY:	SAMPLE: PURIFICATION WORKS	REPORT TO:
	SOURCE: FINAL FLOW 08:50	
EH Sarah Baartman District Municipality	Sample Ref: 5	EH Sarah Baartman District Municipality
PO Box 318	Client Ref No: 5	PO Box 318
Port Elizabeth	Outbreak Case No:	Port Elizabeth
Eastern Cape	Collected: 17/08/2026 08:50	Eastern Cape
6000	Received: 17/08/2026 12:25	6000
	1st Print: 21/08/2026 15:09	
	Reprint: 21/08/2026 15:10	

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	Acceptable
Date of testing	17/08/2026
Coliform count (Colilert)	4 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03080539

SAMPLE: FINAL RESIVIOR
SOURCE:

SUBMITTED BY:

EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

Sample Ref: RIEBEECK EAST
Client Ref No: RIEBEECK EAST
Outbreak Case No:
Collected: 17/08/2026 12:19
Received: 17/08/2026 12:25
1st Print: 21/08/2026 15:19
Reprint: 21/08/2026 15:19

REPORT TO:

EH Sarah Baartman District Municipality
PO Box 318
Port Elizabeth
Eastern Cape
6000

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	Acceptable
Date of testing	17/08/2026
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --

FULL FINAL LABORATORY REPORT

LAB NUMBER: UH 03080534

SUBMITTED BY:	SAMPLE: EXT 7 CLINIC	REPORT TO:
	SOURCE: TAP WATER 08:28	
	Sample Ref: 4	
	Client Ref No: 4	
	Outbreak Case No:	
EH Sarah Baartman District Municipality	Collected: 17/08/2026 08:28	EH Sarah Baartman District Municipality
PO Box 318	Received: 17/08/2026 12:25	PO Box 318
Port Elizabeth	Printed: 21/08/2026 15:08	Port Elizabeth
Eastern Cape		Eastern Cape
6000		6000

PUBLIC HEALTH

Specimen received: Filtered water
Tests requested: Potable water

Potable Water:

Condition on arrival	On ice
Date of testing	17/08/2026
Coliform count (Colilert)	0 per 100ml
E coli count (Colilert)	0 per 100ml

WATER DOMESTIC
ESSENTIAL MICROBIOLOGICAL CRITERIA AS PER SANS 241
Total bacterial count.....<=1000 per mL
Total coliforms.....<=10 per 100mL
Escherichia coli.....Absent in 100mL

The above test result relates only to the item/sample as received
This report shall not be reproduced except in full, without the approval of the laboratory.

REFERENCE METHOD(S):

Coliform Count - Colilert Method.....Colilert SANS 5521
E.coli Count - Colilert Method.....Colilert SANS 5521

Authorised by: M Marais (Medical Technologist) Potable water

-- End of Laboratory Report --